

**The company** **ORBIS TECNOLOGÍA ELÉCTRICA, S.A.**  
c. Lérida, 61  
28020 Madrid  
Spain

We declare under our sole responsibility that

**the product** **CONTAX D 8043 S0 MID**  
Poly phase, active import, indoor, Electricity Meter for the energy measurement ,  
Voltage rating: 3x230/400 V,  
Current range: 0,25-5(30) A, 0,25-5(32) A, 0,25-5(40) A, 0,25-5(45) A, 0,25-5(50) A,  
0,25-5(60) A, 0,25-5(80) A,  
Frequency: 50 Hz;  
LED pulse constant: 800 imp/kWh

Is in conformity with the relevant Union harmonisation legislation:


**Directive 2014/32/UE (MID)** of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of measuring instruments (Official Journal of the European Union, L96/149, 29/03/2014);

And it is in conformity with the following applicable standards: EN 50470-1:2006 "Electricity metering equipment (a.c.) - Part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)"  
EN 50470-3:2006 "Electricity metering equipment (a.c.) - Part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)"

And is in conformity with the type as described in the **EU-type examination certificate SGS0296** issued by  
**Notified body No. 0120**  
**Body name: SGS United Kingdom**

**Additional information** This product is intended to be installed and maintained by a professional.  
All records relating to assembly, inspection, identification and traceability shall be kept for not less than 10 years.

Place and date of issue: Madrid, 2017-04-20

  
ORBIS TECNOLOGÍA ELÉCTRICA, S.A.  
C/ Lérida, 61 28020 MADRID